



EVACUATION ROUTES FOR AMC SATELLITE ANATOMIC PATHOLOGY LABORATORIES

There are six satellite Anatomic Pathology processing laboratories located on the Anshutz Medical Campus: AOP 3126, AOP 6118, and AIP B.2305.25, AIP B.2312, AIP B2309, AIP B2309.1. In keeping with the University of Colorado Denver's Fire and Safety Policy the following procedures have been adopted:

1. There is an evacuation map located in each of these labs immediately adjacent to the door. This map indicates those evacuation routes that lead to the nearest staircase or egress.
2. In the event that the person evacuating the area is unable to use the staircase of the building, i.e. due to physical disabilities, the inner door of the staircase provides a fire safe space for two hours. The person evacuating is to stay contained within this space until fire and rescue arrives.
3. Adhering to the RACE policy (rescue, alarm, contain, and extinguish) it is expected that all employees within an area are to check all rooms and to close all doors of their area when evacuating. Should a person working within a lab have an auditory disability, it is expected that other employees evacuating adjacent areas would alert that person to the alarm and the need to leave the area.

GEN.73900

Approval of Procedure:

Medical Director Signature: *SM. Scott Zamora*

Date: 8/29/12

